

LDNSF 12.3.56
08/02/96

PR

Form 63-11.1, (1/89)

4. Longview Fibre Co. (LFC) is subject to requirements of 40 CFR 60 Subpart Dc and shall notify EPA of the installation.
5. LFC shall operate these boilers using No. 2 oil with no more than 0.05% sulfur. Records shall be maintained for a period of two years and made available to PSAPCA personnel upon request.
6. Within 180 days of startup of the boilers, LFC shall perform a compliance test according to Regulation I, Section 3.07, to demonstrate compliance with the NOx and CO limits in Condition No. 7.
7. The emissions of this boiler shall not exceed any of the following:
 - a. NOx = 0.05, CO = 0.05, SO2 = 0.01, VOC = 0.02 lb/MMBtu one-hour average on natural gas.
 - b. NOx = 0.20, CO = 0.10, SO2 = 0.60, VOC = 0.05 lb/MMBtu one-hour average on No. 2 oil.
 - c. PM-10 = 0.02 gr/dscf @ 7% O2.
 - d. Source test methods are EPA Methods 6C for SO2, 7E for NOx, 10A for CO, and 25A for VOC; and PM-10 by PSAPCA procedure in Resolution 540 dated Aug 11, 1993.
8. It shall be unlawful for LFC to cause or allow the emission of any air contaminant from this boiler which exceeds 10% opacity according to EPA Method 9.

☐ See Attachment